

Certificate

Certificate No: 40084/5

Issue No: 1

Date of issue: 12 October 2007

This is to certify that

BSRIA Limited

has Type Tested the emergency smoke ventilator described below in accordance with the test methods contained within BS EN12101-3: 2002, Clauses 5 and 6.1 to 6.7 and has determined that the item met the requirements of the standard for the time and temperature classes listed.

Date of Test	05/09/07
BSRIA Test Item Number	40084B1MAR
Ventilator Details	
Ventilator Supplier	ExcelAir
Ventilator Model	CPC 250-4-S
Ventilator Serial Number	00278
Motor Details	
Motor Manufacturer	WEG
Motor Model	3~90S-4, 1.5 kW
Motor Serial Number	QC20960
Test Conditions	
BS EN 12101-3 Test Class	F300 Unclassified, 300°C, 2 hrs
Application Classes	Un-insulated Smoke reservoir Dual purpose No ducted cooling air required
Test Set-up	Horizontal Immersed Centrifugal fan with motor in airstream
Certificate Details	
Client	ExcelAir
Client Address	Postbus 3093 3301 DB Dordrecht Netherlands
Date of issue	12 October2007
Date of expiry	12 October2010

Quality Approved PHIL STONARD
Principal Engineer
MicroClimate & Test

Full details are shown in BSRIA Report Number 40084/3, available from the client. To authenticate this certificate, visit www.bsria.co.uk/certificates, or contact BSRIA Limited.